

Chief of Department
Keith Stark

Fire Alarm Superintendant

Lt. Thomas Murphy
tmurphy@weymouth.ma.us

Fire Prevention

F/F Justin Myers
jmyers@weymouth.ma.us

***Weymouth
Fire Department***



636 Broad Street
Weymouth, MA 02189
781-337-5151
FAX: 781-340-5024

www.weymouth.ma.us

Service, Pride, Commitment

Minimum Contractor Requirements Heat Treatment Bed Bug Extermination

1. Applications must be received by the Fire Department a minimum of 48 hours prior to the desired treatment date. Applications received Friday through Sunday will not be considered until Monday.
2. A permit shall be required to shut off, disconnect, disable, or otherwise remove any device used for fire protection. (MGL 148 § 27A)
3. If using a portable generator a permit may be required for the temporary storage and use of Flammable / combustible liquids. (527CMR14)
4. If using Propane heaters a permit may be required for the temporary storage and use of LPG. (527CMR6) (May require additional carbon monoxide detectors)

Applications shall be comprehensive and include all of the following supporting documentation.

5. Name, address, and telephone # of the company performing the treatment.
6. Name and cell phone number of the person representing the treatment company onsite at all times.
7. Name, address, and telephone # of the company conducting fire alarm or sprinkler system work.
8. A project narrative to include the plan for treatment, the schedule, and procedures to take in the event of an actual alarm.
9. Site plan showing the proposed location of the generator and or heating units.
10. Applications shall be accompanied by a check made payable to the Town of Weymouth in the amount of (\$50.00 per permit application)
11. **INCOMPLETE APPLICATIONS WILL NOT BE CONSIDERED!**

General Procedures

- Contractor shall provide appropriate protection of the sprinkler heads, smoke detectors, and heat detectors in treated units.
- Fire Department shall be notified when the work is started and completed by calling Fire Alarm Dispatch at 781-337-5151 and referencing the address and unit number if applicable.
- A representative of the Property and/ or pest management company shall monitor affected areas at all times.
- If any fire, smoke or other hazardous condition is observed, the fire alarm system shall be activated by pull station to sound the alarms to evacuate the building. The fire department shall be called via 911.
- If an accidental activation of the system occurs, the fire department shall be notified at 781-337-5151. The fire department will respond to investigate the alarms. The horns will be reset by the fire department.
- No other work or testing shall be done on any fire protection system without prior approval of the fire department.